



STC RATING DATA

Series Model	Test Number	Date of Test	Test Size	Glazing (Nominal)	STC	OITC
Element Fixed Window	D7523.01-113-11	5/14/2014	47-1/4" x 59"	3/4" IG (3/16" tempered exterior, 5/16" air space, 1/4" laminated interior)	34	29
Element Series Single Hung Window	D7524.01-113-11	7/24/2014	47-1/4" x 59"	3/4" IG (3/16" annealed exterior, 7/16" argon, 1/8" annealed interior)	32	27
Element Series Single Slide Window	D7525.01-113-11	5/14/2014	59" x 47-1/4"	3/4" IG (3/16" tempered exterior, 5/16" air space, 1/4" laminated interior)	34	29